

BARRELS PER HOUR	FLOW FT.³ per MIN.	P.S.I.
1423	133	1.25
3371	315	1.26
5339	499	1.03
7287	681	1.02
9266	866	1.09
11246	1051	1.16
12979	1213	1.20

Curve for *PRESSURE* side of 8" Equate PV Valve - *1.0 PSI*

CEESI - Colorado Engineering

data based on air flow

ELECTROMECHANICAL RESEARCH LABORATORIES, INC.
P.O. 1026 NEW ALBANY, IN 47150

DATE 6/17/08	DRAWN D. URBAN	PART NAME Flow Curve 1.0 PSI Pressure	
TOLERANCES .0= +/- .030 .00= +/- .015 .000= +/- .005	APPROVED	UNIT NAME 8" Equate PV Valve	
	SCALE / JOB NO.	DRAWING NO. 169T143B	ITEM NO.